

Certificate of Compliance

FIRE PROTECTION EQUIPMENT

This certificate is issued for the following equipment: Blendaire Gas-Air Mixer

Approval Guide Listing: Category:

■Flammable Gas Equipment ■LP-Gas Vaporizer-Mixers

Algas-SDI International LLC 151 S Michigan St Seattle, WA 98101 United States

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Approval Report(s), of the following FM Approval Standards and other documents:

Approval Standards Class Number 7157

Date January 1990 Other Standards Organization, Designation Date

Original Approval Job Identification:0003059970

Approval Granted: 19 March 2017

Related Report:

Subsequent Revisions:

To verify the availability of the Approved product, please refer to www.approvalguide.com

8. Marguerdint

J/E. Marquedant Manager of Electrical Systems FM Approvals 1151 Boston-Providence Turnpike, Norwood MA, 02062 USA 19 March 2017

Date



Member of the FM Global Group



Certificate of Compliance

Blendaire LP Gas-Air Mixer

BLENDAIRE LP Gas-Air Mixer. Models B20, B45, B80, B135, B330, B750, B1250, B1700. Model numbers indicate nominal capacity in millions of Btu/hr (1 million Btu/hr = 293 kW). The BLENDAIRE is available in NEC Class I, Division 1, Group D and Class I, Division 2, Group D configurations



Member of the FM Global Group